



**ADDENDUM NO. 4
Issued June 28, 2007**

TO

**REQUEST FOR BIDS
FOR
HARTFORD LANDFILL CLOSURE
MSW/INTERIM ASH DISPOSAL AREA
(RFQ Number 2007E005)**

(RFB Issued June 4, 2007)

Note: Bidder is required to acknowledge this and all Addenda in Section 5(a) of the Bid Form.

The following is the fourth addendum being issued as part of the bid solicitation by the Connecticut Resources Recovery Authority (“CRRA”) for the subject project. All bidders must acknowledge receipt of this addendum in the appropriate space on the Bid Form in order for the bid to be deemed responsive. This addendum is divided into several parts and reference is made to additional and revised documents being issued as part of this addendum. The bidders are responsible for completely reviewing the addendum and shall adjust their bid based upon the original Bid Documents and the changes incorporated by this addendum.

1. MODIFICATIONS TO THE CONTRACT DOCUMENTS

Bidders are notified that the proposed contours depicted on Sheets CG-101 thru CG-104 (Subgrade Plan) are the top of cover system contours. The correct subgrades contours are 2 feet lower than elevations provided. The spot elevations provided in the western drainage ditch are correct.

Please note that in accordance with the notes on the affected pages, proposed grades may be altered in the field based on availability of suitable on-site fill material. Contractor will ensure that all surfaces meet slope requirements (i.e., minimum of 4% and maximum of 33%).

The proposed final contour depicted on Sheets CG-111 thru CG-114 are correct and are not effected by this addendum.

Revised drawings will be issued to the successful bidder after execution of the agreement.

END OF ADDENDUM NO. 4