

CONSTRUCTION NOTES

- REFER TO STRUCTURAL DRAWINGS FOR FRAMING PLANS AND DETAILS.
- THE HOIST INSTALLER WILL DESIGN AND INSTALL THE MONORAIL HOIST ELECTRIFICATION SYSTEMS INCLUDING THE MOTOR, MOTOR ELECTRIFICATION, PUSH BUTTON CONTROL ELECTRIFICATION, TROLLEYS AND SUPPORTS. COORDINATE FINAL CONNECTIONS OF 3 Ø POWER AT EACH HOIST WITH THE HOIST INSTALLER. CONDUIT ROUTING BELOW GRATING SHALL BE INSTALLED PARALLEL TO FRAMING MEMBERS AND SUPPORTED AT EACH JOIST WHEN NOT SUPPORTED ALONG BEAMS.
- PROVIDE GROUNDING OF HOIST CRANE NON-CURRENT-CARRYING METAL PARTS IN ACCORDANCE WITH NEC ARTICLE 610.61.

)		
NOITAINOSAU	SYMBOLS	

URS CORPORATION AES 500 ENTERPRISE DRIVE ROCKY HILL, CT 06067 1-(860)-529-8882

PROFESSIONAL

SEAL

SYMBOL	DESCRIPTION
Q	ELECTRIC MOTOR (ID TAG AS INDICATED)
Þ	FUSED DISCONNECT SWITCH
\boxtimes	MOTOR CONTROLLER
	JUNCTION BOX — SIZE PER NEC
	BRANCH CIRCUIT WIRING — WIRE & CONDUIT SIZE AS INDICATED
	ELECTRICAL FINAL CONNECTION TO EQUIPMENT

WEATHERPROOF	WP
WATT	W
VOLT-AMPERE	VA
VOLTS	<
UNLESS NOTED OTHERWISE	ONO
TIME DELAY	TD
NFPA 70, NATIONAL ELECTRICAL CODE	NEC
MOTOR CONTROL CENTER	MCC
KILO-WATT	XW
KILO-VOLT-AMPERE	KVA
KILO-VOLT	X
GALVANIZED RIGID CONDUIT	GRC
GENERAL CONTRACTOR	G.C.
GROUND	G
ELECTRICAL CONTRACTOR	E.C.
CIRCUIT BREAKER	C/B
CONDUIT	С
AMERICAN WIRE GAGE	AWG
AUXILIARY	AUX
AMPERE INTERRUPTING CAPACITY	AIC
ABOVE FINISHED GRADE	AFG
ABOVE FINISHED FLOOR	AFF
AMPERE	Α
EXTENSION	ABBREVIATION
ABBREVIATIONS	ABI

E101

E101

ELECTRICAL PLANS, NOTES, SYMBOLS AND ABBREVIATIONS

DATE:

02/13/07

DRAWING

 \mathcal{O}

유

O

SCALE:

AS NOTED

CRRA
PBF WAREHOUSE
HOIST CRANE FRAME

RESERVE ROAD HARTFORD, CT

TEL. NO. (860)-757-7700 FAX. NO. (860)-757-7743 CONNECTICUT

RESOURCES

RECOVERY

AUTHORITY