



ADDENDUM NO. 1
Issued August 16, 2007
TO
“REQUEST FOR BIDS
FOR
UPGRADE OF THE AUTOMATION SYSTEM AT THE
MID-CONNECTICUT WASTE PROCESSING FACILITY”
(Bid Number 08-O-002)
(RFB Issued July 25, 2007)

Note: Bidder is required to acknowledge this and all Addenda in Section 5(a) of the Bid Form.

This Addendum consists of the Connecticut Resources Recovery Authority’s (CRRA) response to written question that have been received by CRRA through August 15, 2007, the deadline for questions as specified in the RFB.

1.	Question	Where are the BCD interface cards located for the drives that are going to be converted to 4-20 ma reference signals? Are the BCD interface cards in the PLC rack enclosure or are they in the drive enclosure?
	Answer	The BCD interface cards are located in each individual conveyor’s drive (either Allen Bradley 1334 or 1336 drives) enclosure.
2.	Question	Is it the intent of the automation upgrade project to eliminate the line printer and associated basic module? Will the basic modules need to stay?
	Answer	Yes, the intent of the automation upgrade project is to eliminate the line printer and associated basic module. The basic modules do not need to stay.