MECHANICAL NOTES

1. REMOVAL AND INSTALLATION OF CEILING IS BY OTHERS.
2. PROVIDE BRANCHING DAMPERS AT ALL BRANCH DUCTS SERVING DIFFUSERS.
3. FOR MAINTENANCE CATWALK, SEE ARCHITECTURAL SECTION DWG. AND STRUCTURAL DWGS.



1 CONTROL ROOM / VISITOR AREA - UPPER ATTIC MECHANICAL PLAN

SCALE: 1/8" = 1'-0"

NOTE: CEILING IMPROVEMENTS NOT IN CONTRACT, COORDINATE AIR OUTLET LOCATIONS WITH OWNER.

PROJECT NORTH

CONNECTICUT RESOURCES RECOVERY AUTHORITY
TEL. NO. (860)-757-7700
FAX. NO. (860)-757-7743

A&E FIRM

URS
URS CORPORATION AES
500 ENTERPRISE DRIVE
ROCKY HILL, CT. 06067
1-(860)-529-8882

A&E SEAL

THE INFORMATION CONTAINED IN THIS SET OF DOCUMENTS IS PROPRIETARY BY NATURE. ANY USE, DISCLOSURE OTHER THAN THAT WHICH RELATES TO CRRA AND MDC IS STRICTLY PROHIBITED.

REVISIONS

NUMBER	DATE	REMARKS

CONTROL ROOM HVAC SYSTEMS IMPROVEMENT

300 MAXIM ROAD
HARTFORD, CT.

PROJECT NO:	36937520.00001
DRAWN BY:	PA
CHECKED BY:	VMD
DATE:	04/28/08
CADD FILE:	AS NOTED

CONTROL ROOM/ VISITOR AREA MECHANICAL PLAN

M-101

P:\Disciplines\Mechanical\Sheet\M-101.dwg April 30, 2008 - 11:24 AM