



**ADDENDUM NO. 1  
Issued September 22, 2008**

**TO**

**“REQUEST FOR BIDS  
FOR  
MID-CONNECTICUT WASTE PROCESSING FACILITY  
SECONDARY SHREDDER MOTOR CONVERSION”  
(RFB Number FY09-OP-002)  
(RFB Issued August 29, 2008)**

**Note: Bidders are required to acknowledge this and all Addenda in Section 5(a) of the Bid Form.**

This Addendum consists of a change to the RFB Package Documents by the Connecticut Resources Recovery Authority (“CRRA”) related to prevailing wage requirements and CRRA’s responses to written questions that were received by CRRA by 3:00 p.m., September 19, 2008, the deadline specified in the Instructions To Bidders for the submission of written questions.

**1. Prevailing Wage Requirements**

CRRA has determined that Connecticut’s prevailing wage requirements do not apply to this Project. Therefore, CRRA is, by the Addendum, deleting all references in the RFB Package Documents, including the Agreement, to prevailing wage requirements and, where necessary, renumbering the remaining sections and or exhibits accordingly.

**2. Additional Workscope Requirements**

CRRA is requiring bidders to perform a dynamometer test on each newly converted 1250 HP secondary shredder motor. Prior to CRRA receiving each newly converted 1250 HP secondary shredder motor CRRA will review the dynamometer report.

**2. Responses To Written Questions**

The following are CRRA’s responses to written questions received on the RFB Package Documents.

<b>1.</b>	Question	Can CRRA provide a motor dimensional drawing of the existing 1000 HP motor?
	Answer	CRRA will include as part of this addendum.
<b>2.</b>	Question	Number of rotor bars on existing 1000 HP motor?
	Answer	75
<b>3.</b>	Question	Stator identification number on existing 1000 HP motor?
	Answer	28
<b>4.</b>	Question	Stator length on existing 1000 HP motor?
	Answer	23 inches (iron length)
<b>5.</b>	Question	Current versa-PAC info. On existing 1000 HP motor?
	Answer	Current 1000 HP motor stator does not have a versa-PAC.

<b>6.</b>	Question	Can CRRA provide of the technical manual for existing 1000 HP motor?
	Answer	No, neither CRRA nor its operator has a technical manual.
<b>7.</b>	Question	Confirmation to confirm if prevailing wage applies for work occurring in our facility.
	Answer	Yes, any work that is performed on CRRA's existing site does apply to prevailing wage requirements. Although, as highlighted in the bid the existing 1000 HP motors would be shipped off-site to bidder's facility- therefore prevailing wage would not apply as stated above in response #1.
<b>8.</b>	Question	Does CRRA require a performance bond for in house work?
	Answer	As stated in the bid, CRRA is requiring a performance and payment bond.
<b>9.</b>	Question	
	Answer	
<b>10.</b>	Question	
	Answer	
<b>11.</b>	Question	
	Answer	
<b>12.</b>	Question	
	Answer	
<b>13.</b>	Question	
	Answer	
<b>14.</b>	Question	
	Answer	
<b>15.</b>	Question	
	Answer	

<b>16.</b>	Question	
	Answer	
<b>17.</b>	Question	
	Answer	
<b>18.</b>	Question	
	Answer	